



Last update 22/11/2017 99500 - Page 1 of 2

TEC[™] 801 Copper Tape

Self-adhesive copper tape for the installation of electrically conductive floor coverings

APPLICATION

Establishment of the potential equalization for the electrically conductive installation of floor covering

TECHNICAL DATA

Basis Electrolyte copper foil Roll dimension Length : 20 m

Width: 10 mm Thickness: 0,1 mm

Packaging Cardboard box containing 30 rolls

Storage condition In a temperate (5 °C - 25°C) and dry room.

APPLICATION

Follow the instructions of the floor covering manufacturer regarding the method of installations: Examples:

- Apply the dispersion Primer TEC 041 on the well-prepared sub-floor. Stick an approx. 1 m long copper tape stripe onto the sub-floor acc. to an electrician's advice. The stripe needs to be a bit longer than the floor-covering in order to be adhered onto the wall by an electrician for establishing a potential equalization.
- The TEC 801 Copper tape may be applied on the well-prepared sub-floor instead of using the Primer TEC 041. Please make sure that
 the Copper Tape 801 is underneath each floorcovering strip and on the top side of the room there is one cross connection on the subfloor.

Each 30 m² area needs a potential equalization. Make sure that there is no point more far away than 9-10 m from the next copper tape (e.g. long corridors).

TEC [™] 801 Copper Tape	Technical Dat	a Sheet
i E O OO i OOppei lape	I Commodi Dat	a Onoct

95500 - Page 2 of 2

www.tecspecialty.com/europe



 $\hbox{H.B. Fuller Adhesives France SAS-56, rue du Général de Gaulle-67250 Surbourg-France} \\$

IMPORTANT: Information, specifications, procedures and recommendations provided ("information") are based on our experience and we believe this to be accurate. No representation, guarantee or warranty is made as to the accuracy or completeness of the information or that use of the product will avoid losses or damages or give desired results. It is purchaser's sole responsibility to test and determine the suitability of any product for the intended use. Tests should be repeated if materials or conditions change in any way. No employee, distributor or agent has any right to change these facts and offer a guarantee of performance.

NOTE TO USER: by ordering/receiving product you accept the H.B. Fuller General Terms and Conditions of Sale applicable in the region. Please request a copy if you have not received these. These Terms and Conditions contain disclaimers of implied warranties (including but not limited to disclaiming warranties of fitness for a particular purpose) and limits of liability. All other terms are rejected. In any event, the total aggregate liability of H.B. Fuller for any claim or series of related claims however arising, in contract, tort (including negligence), breach of statutory duty, misrepresentation, strict liability or otherwise, is limited to replacement of affected products or refund of the purchase price for affected products. H.B. Fuller shall not be liable for loss of profit, loss of margin, loss of contract, loss of business, loss of goodwill or any indirect or consequential losses arising out of or in connection with product supply.

Nothing in any term shall operate to exclude or limit H.B. Fuller's liability for fraud, gross negligence or for death or personal injury caused by negligence or for breach of any mandatory implied